

Betriebsdaten Übersicht

Modul Typ: FWM 30 PM

Thermostatkopfeinstellung	Vorlauftemp. (°C)	Zapfmenge l/min - WW Temperatur / Rücklauftemperatur °C															
		35		30		25		20		15		10		5			
		WW	RL	WW	RL	WW	RL	WW	RL	WW	RL	WW	RL	WW	RL		
45	50 °C	30,05	15,33	31,41	16,01	32,64	16,35	33,36	17,07	35,72	17,77	38,32	19,38	41,94	23,25		
	55 °C	31,89	15,68	33,04	16,18	34,19	16,41	35,66	16,92	37,21	17,53	40,38	19,16	42,93	21,23		
	60 °C	33,76	15,89	34,81	16,33	35,78	16,61	37,30	17,02	39,43	17,93	42,41	19,18	44,66	20,42		
	70 °C	34,15	15,06	35,05	15,18	36,22	15,31	37,96	15,67	40,24	16,39	42,55	16,99	44,31	17,71		
	90 °C	36,81	13,54	37,77	13,73	39,27	13,95	41,18	14,22	43,17	14,59	44,39	14,64	45,15	14,80		
50	50 °C	30,39	15,42	32,64	16,53	35,66	18,26	37,60	19,46	39,36	20,61	41,71	22,40	44,95	27,92		
	55 °C	33,10	16,21	36,33	17,71	37,62	18,34	39,14	19,00	40,95	19,75	43,65	21,46	47,38	25,31		
	60 °C	35,84	16,60	38,05	17,64	39,64	18,40	41,09	18,92	42,91	19,64	46,12	21,40	49,19	24,36		
	70 °C	37,95	16,49	38,75	16,72	39,96	16,91	41,48	17,21	43,56	17,80	46,76	19,15	48,85	19,83		
	90 °C	40,46	14,47	41,73	14,50	42,99	14,57	45,00	14,95	47,27	15,32	49,30	15,60	50,61	15,93		
55	50 °C	30,26	15,25	32,50	16,37	35,88	18,22	39,83	21,13	42,70	23,88	44,65	26,52	47,05	32,74		
	55 °C	33,15	16,22	35,92	17,44	39,82	19,55	42,30	21,30	44,35	22,63	46,78	24,72	50,26	30,82		
	60 °C	36,79	16,55	38,87	17,99	42,81	20,08	44,97	21,33	46,76	22,39	49,19	24,22	53,09	29,93		
	70 °C	40,15	17,35	42,12	18,20	43,71	18,85	45,28	19,10	47,15	19,75	50,52	21,43	53,30	23,16		
	90 °C	44,96	17,28	45,87	17,40	47,23	17,59	48,96	17,96	51,40	18,49	53,87	19,24	55,27	19,40		
60	50 °C	30,27	15,60	32,92	16,91	35,70	18,41	39,61	21,31	43,73	25,58	46,82	31,68	47,94	39,24		
	55 °C	33,08	15,95	35,57	17,25	39,34	19,34	43,84	22,50	47,40	26,00	49,81	29,28	51,97	35,99		
	60 °C	36,26	17,51	38,97	18,83	43,16	21,06	47,59	24,12	49,98	26,59	52,15	29,01	55,04	36,15		
	70 °C	41,23	18,18	44,32	19,48	47,88	21,36	49,70	22,21	51,58	23,21	54,17	24,59	57,89	28,52		
	90 °C	49,32	19,08	50,17	19,24	51,58	19,40	53,06	19,78	55,25	20,20	58,47	21,17	60,29	21,79		
65	50 °C	30,71	15,63	32,81	16,58	35,90	18,38	39,88	21,24	44,18	25,96	47,18	31,98	48,30	39,91		
	55 °C	33,10	15,82	35,67	16,96	39,47	19,18	43,94	22,32	48,64	26,94	52,51	34,33	53,73	42,19		
	60 °C	36,57	17,56	39,02	18,72	43,35	20,95	47,67	24,02	53,12	29,49	55,70	34,47	57,46	42,55		
	70 °C	41,34	18,17	44,73	19,68	49,74	22,24	53,69	24,86	55,74	26,20	58,12	27,88	62,12	33,51		
	90 °C	51,20	19,61	54,37	20,84	55,91	21,42	57,53	21,79	59,52	22,03	62,69	23,24	65,09	24,24		
70	50 °C	30,15	15,42	32,42	16,46	35,58	18,20	39,37	20,80	43,71	25,24	47,10	31,83	48,31	40,04		
	55 °C	32,67	15,67	35,63	16,99	39,33	19,04	43,65	22,02	48,69	27,20	52,48	34,42	54,01	44,08		
	60 °C	36,30	17,53	39,32	19,04	43,36	21,38	47,87	24,22	53,13	29,65	57,38	38,65	58,56	47,37		
	70 °C	41,08	18,33	44,92	19,88	49,72	22,25	55,72	26,32	59,59	30,14	62,04	32,87	65,30	40,20		
	90 °C	51,92	20,35	57,16	22,47	59,85	23,55	61,66	24,05	63,68	24,61	66,84	25,96	69,80	27,52		

*Bemerkung: Kaltwassertemperatureingang 10°C